

CHAPTER 3

LIQUEFIED PETROLEUM GAS CODE

SECTION:

- 5-3-1: Definition
- 5-3-2: Enforcement
- 5-3-3: Odorizing
- 5-3-4: Containers
- 5-3-5: Equipment
- 5-3-6: License for Production
- 5-3-7: License for Storage
- 5-3-8: Storage
- 5-3-9: L-P Code on File

5-3-1: DEFINITION: The term liquefied petroleum gases as used in this Chapter means any material composed predominantly of propane, propylene, butane (normal butane or iso-butane) and butylene or a mixture of them. (1963 Code, * 18.01)

5-3-2: ENFORCEMENT: No person shall produce, store or use liquefied petroleum gas, or install or maintain any equipment for such production or use, unless such production, storage and utilization equipment is constructed and maintained in compliance with the provisions of this Chapter. The Fire Chief, or such other officer or employee as may be designated by the President, shall enforce the provisions of this Chapter and make such inspection or tests as may be necessary in connection therewith. Wherever a test is necessary to determine whether any equipment or method complies with the standards prescribed or referred to in this Chapter, the enforcing official may accept the results of a test conducted by or under the supervision of the Underwriters Laboratories, Inc. (1963 Code, * 18.02)

5-3-3: ODORIZING: All liquefied petroleum gas used or stored in the Village shall be effectively odorized by an agent of such character as to indicate by a distinctive odor the presence of gas in the air down to a concentration of 1:50 the lower limit of combustibility. (1963 Code, * 18.03)

5-3-4: CONTAINERS: All containers used for liquefied petroleum gases shall be constructed according to the standards prescribed therefor in the "Standards of the National Board of Fire Underwriters for the Storage of Liquefied Petroleum Gases" as published in May, 1960 in pamphlet form by the National Board of Fire Underwriters, hereinafter referred to as N.B.F.U. pamphlet No. 58. The maximum filling density (the percent ratio of the weight of gas in a container to the weight of water the container will hold sixty (60) degrees F. shall be that prescribed in paragraph B. 12 of N.B.F.U. pamphlet No. 58. No such container in use in connection with any building shall be located between the building and the street upon which the building abuts, nor within

such building. The installation of such containers and location with reference to buildings shall be in accordance with the standards prescribed in N.B.F.U. pamphlet No. 58. (1963 Code, * 18.04)

5-3-5: EQUIPMENT: No equipment for the utilization of liquefied petroleum gas shall be installed in the Village unless a permit is fifteen dollars (\$15.00), except that when such installation is in a building being newly constructed or remodeled in accordance with a permit for such construction and remodeling, no extra fee for such a permit is required. Application for such permit shall be made to the Clerk and shall contain a description of location, equipment, and intended use of such equipment. No equipment shall be installed or used unless it complies with the standards therefor established in the N.B.F.U. pamphlet No. 58. (1963 Code, * 18.05)

5-3-6: LICENSE FOR PRODUCTION: No person shall operate a plant for the production of liquefied petroleum gases, or for filling containers with such gas, in the Village without first having obtained a license therefor. The annual fee for such license is fifty dollars (\$50.00). No such license shall be issued unless the premises and equipment thereon to be used in such activity are in full compliance with the standards prescribed in N.B.F.U. pamphlet No. 58 and no person shall conduct or operate such activity unless all buildings and equipment used in connection therewith comply with the standards prescribed in that bulletin. (1963 Code, * 18.06)

5-3-7: LICENSE FOR STORAGE: No person shall engage in the business of storing liquefied petroleum gases in the Village without having first secured a license therefor. The annual fee for such a license is fifty dollars (\$50.00). No license shall be issued unless the premises and equipment thereon to be used in such activity are in full compliance with the standard prescribed in N.B.F.U. pamphlet No. 58, and no person shall conduct or operate such activity unless all buildings and equipment used in connection therewith comply with the standards described therein. (1963 Code, * 18.07)

5-3-8: STORAGE: No liquefied petroleum gases shall be stored in the Village except in compliance with the standards set in N.B.F.U. pamphlet No. 58. (1963 Code, * 18.08)

5-3-9: L-P CODE ON FILE: The Clerk shall keep on file three (3) copies of the N.B.F.U. pamphlet No. 58, dated May, 1960, for public inspection. (1963 Code, * 18.09)